

STABILITY CERTIFICATE

Property At :


M/s. I C F VIDYANIKETAN,
Apprentice Avenue, I C F Colony,
Konnur High Road, Chennai-600 038.


Dates :

04-12-2020 to 03-12-2023 (Three Years)

Dr. B.N. GUPTA, BE, MSc (Engg), PhD, FIE (India)
FIV, FIGS, MSET
Chartered Engineer, Registered Valuer & Geotech Consultant,
Director : Prasad Armstrong Yen GEC (P) Ltd.
Partner : Revier Constructions
No.13 (Old No.6) Damodara Murthy Road,
Kilpauk, Chennai-600 010.

Mobile : 98406 31653
Phone : 2644 3164(R)
2363 7146(O)


MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.


PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.

FORM OF APPLICATION UNDER SUB-SECTION (1) (SUB-SECTION 2) OF SECTION 4 OF THE MADRAS
PUBLIC BUILDING ACT (LICENSING) ACT 1965 (MADRAS ACT 13 OF 1965) REFERRED TO IN RULES
OF THE MADRAS PUBLIC BUILDINGS (LICENSING) RULES 1966

From

M/s. ICF VIDYANIKETAN,
Apprentice Avenue, I.C.F. Colony,
Konnur High Road, Chennai - 600 038.

To

The Collector of Chennai
Chennai Collector's Office
Rajaji Salai, Chennai 600 001.

1. I intend to use the building / to continue to use the existing public building / to use the existing building not to present used as a public building which is situated in the site or plot of land, Town or Survey No. / Door No. - Apprentice Avenue, I.C.F. Colony, Konnur High Road, Chennai - 600 038 for the period from 04-12-2020 to 03-12-2023 (Three years).
2. The year of construction and the present approximate cost of construction and purpose for which it is to be used or is being used as public building are also furnished in the Statement accompanying this application.
3. I enclose a Challan of Rs. _____.
4. I also enclose a certificate of structural soundness in the prescribed form furnished by engineer Dr. B. N. Gupta, No. 6, Damodara Murthy Road, Kilpauk, Chennai 600 010.

Dated:

Signature of the Owner

Enclosures:

1. Statement.
2. Challan for Rs. _____ towards the application for renewal of Building License.

EXPLANATION: Separate application shall be made in respect of each building.


MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.


PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.

STATEMENT ACCOMPANYING FORM-A

- Name and Date No. of Building** M.E. I.C.F. VIDYANIKETAN
- Location (Street Name, Ward No., Name of Place (Corporation, Municipality, Panchayat, Panchayat Union, Township, Cantonment))** Approximate Avenue, I.C.F. Colony, Kankar High Road, Chennai - 600 038
(Survey No. 34/1/57 and 18, No. 78, Avanaswaram Village, Chennai)
1985
- Year of Construction**
- Approximate Cost of Construction** About Rs. 11, 00 Lakhs.
- Purpose for which the building is being used or purpose to be used** Proposed CBSE School
- Purpose for which the building hitherto been used**
- Details of construction of the building (particulars) of the foundation soil, specification of the various parts under**
 - Foundation:** Independent RCC column footings.
 - Basement:** Brick work in CM over RCC plinth beam.
 - Superstructure:** Three storied building (G.F + FF + SF), RCC framed structure with brick panel walls in CM, G.F + 2 floors; Masonry C.C. flooring (partly vitrified tiled flooring).
Total Carpet Area is about 7, 700 Sq. Ft.
 - Floor and Roof (are to be given):**
- Period for which license is required** 04-12-2020 to 03-12-2023; Three Years)
- Number of persons to be accommodated** 700 persons

Dated: 02.12.2020



Dr. B. N. Gupte
Dr. B. N. Gupte, B.E., M.S., M.A., M.Tech., Ph.D.
Chartered Engineer, 1982
No. 2853, 7th Floor, K. J. Somaiya Building,
Mumbai - 400 021, India

Signature of the Owner of the Building

[Signature]
MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.

[Signature]
PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.

FORM - B

I certify that the building of M/s. ICF VIDYANIKETAN, Apprentice Avenue, ICF Colony, Konnur High Road, Chennai - 600 038 was inspected on 05-11-2020 mentioned in the statement below. I have satisfied myself that the building structurally sound to be used as a Public Building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS: 895. The scope of this Stability Certificate is limited only to the structural soundness of the subject building (and no other structure in the premises) as per BIS 456 - 2000; this does not include the eventualities caused by natural calamities like cyclone, earthquakes, high gales & storm, lightning, floods, fire etc. Certified that no thatched buildings are used in the premises.



Signature of the Engineer.



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE RV FICE MIBET
Chartered Engineer & Regd Valuer
No.5, Demodara Murthy Road,
Kilbuck, Chennai-600 010.
Ph: 2393 7145 (O) & 25443164 (R)
Mobile: 98406 31853

Certified that no addition or alteration has been made to existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.


If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that we are aware that our license will be cancelled.

Date:

Signature of the Owner of the Building



MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
- ICF, CHENNAI-38.



PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.

FORM - C

(Form of certificate of structural soundness under sub-section (4) of Section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 1 of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

EEEEEEEE

I certify that the building mentioned in the statement and furnished below the salient technical features was inspected.

1. Foundation:

- i. Depth below ground level: 2.13 M
- ii. Nature of soil set out in the foundation level: Clayey Soil
- iii. Pressure at foundation: About 10.00 t/Sq. m.
- iv. Probable safe bearing capacity of strata met at the foundation: About 15.00 t/Sq. m.

2. Superstructure:

- i. Maximum stress in the most critical section of masonry and concrete
 - a. Brick Work in CM = 0.50 kg/Sq.cm
 - b. RCC = 30.00 kg/sq.cm
- Nature of masonry and concrete and its safe permissible stress
 - a. Brick Work in CM = 5.00 kg/Sq.cm
 - b. RCC = 50.00 kg/Sq.cm

The structural soundness of the building has been verified by me with reference to ISI loading standards IS: 895 (latest version) and other relevant Indian Standard code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 04-12-2020 to 03-12-2023 (Three Years).


Date: 02.12.2020
Place: Chennai -10



Signature of the Engineer



Dr B N GUPTA BE M Sci(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.5, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443184 (R)
Mobile: 98405 31853



**MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.**



**PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.**

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, Door No., Street Name, and Name of the Place (1)	Age of the Building (2)	Value of Building at Current Rates (3)	No. of Stories (4)	Short description of structure Steel, RCC framed or Load Bearing in Masonry (5)
M.A. ICF VIDYANIKETAN, Apprentice Avenue, ICF Colony, Konnur High Road, Chennai -600 038.	About 65 years.	About Rs. 11.00 Lakhs.	Three	Three storied building, RCC framed structure with brick panel walls in CMJCF + 2 floors). Mostly CC flooring (partly vitrified tiled flooring)

Purpose for which the building is Certified for use. (6)	Period for which the building will be structurally sound (7)	No. of Persons to be accommodated (8)	Remarks (9)
School	04-12-2020 to 03-12-2023 (Three Years)	770 persons	Building is structurally sound Periodical repairs & proper maintenance is a 'must' for the subject building.

[Handwritten Signature]
02.12.2020

Signature of the Engineer
Designation.



Dr B N GUPTA BE, M Sc Engg Ph.D
M.E. P.W. Engg. MS&ET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010
Ph. 2363 7146 (O) & 26443164 (M)
Mobile: 98400 31653

[Handwritten Signature]

**MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.**

[Handwritten Signature]

**PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.**

PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38

MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38

FORM - E

(Form of Report to be made to the competent authority by inspecting authorities or officers appointed under other act under Section 25 of Madras Public Buildings Authorities Act 1965 (Madras act 13 of 1965) Referred to in rule 7 of the Madras Public Buildings Licensing Rule, 1966.

EEEEEEEE

1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other act or law. : B N Gupta, Panel Engineer (Class IA) of Collector of Chennai for issuing Certificate of Structural soundness of the public buildings.
2. Location of the building inspected D. No., Street name of place, ie., Municipal Corp. / Municipality / Panchayat / Panchayat Union / Township / Cantonment : M/s. I C F VIDYANIKETAN, Apprentice Avenue, I C F Colony, Konnur High Road, Chennai -600-038.
3. Date of Inspection : 05-11-2020.
4. Purpose for which the building is used : Proposed CBSE School
5. Nature of defects noticed : -- Nil --
6. Suggestion for rectifying defects : -- Nil --
7. If in a dangerous conditions immediate action recommended to be taken. : -- Nil --

Date: 02.12.2020


Place: Chennai-10




Signature of Inspecting Authority
Officers appointed or jurisdiction.



Dr B N GUPTA, BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No 6, Damodara Murthy Road,
Kilpauk, Chennai-600 010,
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653



**MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.**



**PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.**



CHENNAI DISTRICT GAZETTE

PUBLISHED BY AUTHORITY

No. 7 J

CHENNAI, AUGUST 3, 2004

Aadi 19, Tharava, Thiruvalluvar Aandu-2035

CONTENTS

	PAGE
Notification by the Collector	15

NOTIFICATION BY THE COLLECTOR.

Approved Panel list of Private Practising Engineers in Chennai district for the purpose of issuing certificate of Structural Soundness of the public buildings.

(Lr. No. V2/59911/2003, 17-6-2004)

The Superintending Engineer, Public Works Department, Buildings Maintenance Circle, Chennai-5 has recommended to elevate and include the name of Dr. B.N. Gupta under Class I-A Panel for Private Practising Engineers.

The Collector of Chennai has approved the name of Dr. B.N. Gupta for elevation and inclusion of his name in the panel of Private Practising Engineers under Class I-A in respect of Chennai district for the purpose of issuing certificate of Structural Soundness of the public buildings under the purview of the Tamil Nadu Public Buildings (Licensing) Act 1966 and Rules issued thereunder.

Chennai,
17th June 2004.

V. KANNUCBAMY,
Collector

[15]

PRINTED BY THE COMMISSIONER OF STATIONERY AND PRINTING AT THE GOVERNMENT BRANCH PRESS,
PUDUKKOTTAI AND PUBLISHED BY THE COLLECTOR OF THE DISTRICT


MANAGER & CORRESPONDENT
ICF VIDYANIKETAN
ICF, CHENNAI-38.


PRINCIPAL
ICF VIDYANIKETAN
ICF, CHENNAI-38.